



DTL-HSE-PER-0005

Excavation / Ground Disturbance Permit

DTL Health & Safety Management System

Doc No: DTL-HSE-PER-0005 **Version:** 1.0 — Apr 2026 **Review:** Apr 2027 **Owner:** Annelize Van Tonder
Linked Procedure: DTL-HSE-PER-0001

Purpose: Required for excavation, trenching or any ground disturbance where there is a risk of striking underground services, ground collapse or falls.

- **Locate underground services** (Dial Before You Dig and potholing) before any ground disturbance. Trenches deeper than 1.5 m require shoring, benching or battering.

1 · Excavation Details

Permit No.	Location
Depth (m)	Date issued
Permit expires	Supervisor

2 · Pre-Excavation Controls

☐ Dial Before You Dig / service plans obtained
☐ Underground services located and marked (potholing)
☐ Excavation method set — shore / bench / batter as required
☐ Spoil set back at least 1 m from the edge
☐ Edge protection / barricading in place
☐ Safe access and egress (ladder within 9 m)
☐ Atmosphere tested for deep or confined excavations
☐ Mobile plant kept clear of the edge

3 · Conditions / Additional Controls

Supervisor

Permit Authorised By

Date

Office use / 2iB: DTL-HSE-PER-0005 · On completion, submit to supervisor within 24 hours and upload the signed record to 2iB.

2iB Ref

Date uploaded

Entered by

Approved for issue



Tyson Knight — Director
27 May 2026

1.0 · Apr 2026 · Initial issue under 2iB numbering (supersedes F025 / DTL-PR-C025) · A. Van Tonder